

## **PIAL Statement of Position**

November 16, 2017

### Stacking Smoke Ejectors

PIAL will not allocate credit for smoke ejectors that are stacked to meet the 5000 CFM standard by the FSRS. A single smoke ejector will be creditable if it meets 5000 cfm based on its shroud rate only. This was accepted by the Advisory Board at this meeting and their vote was unanimous on this item.